



Product Service

CERTIFICATE


No. Z2 16 02 76729 036

Holder of Certificate: Seraphim Solar System Co.,Ltd.

Linnan, Henglin Zhen
 Wujin District
 213101 Changzhou, Jiangsu
 PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.



Test report no.: 704061346608-01

Valid until: 2021-02-02

Date, 2016-02-03

(Zhulin Zhang)

Page 1 of 2



Product Service

CERTIFICATE

No. Z2 16 02 76729 036

Model(s):

SRP-270-6MA, SRP-275-6MA, SRP-280-6MA, SRP-285-6MA,
 SRP-290-6MA, SRP-295-6MA, SRP-300-6MA, SRP-305-6MA,
 SRP-310-6MA, SRP-315-6MA, SRP-320-6MA, SRP-325-6MA,
 SRP-330-6MA, SRP-335-6MA, SRP-340-6MA, SRP-225-6MB,
 SRP-230-6MB, SRP-235-6MB, SRP-240-6MB, SRP-245-6MB,
 SRP-250-6MB, SRP-255-6MB, SRP-260-6MB, SRP-265-6MB,
 SRP-270-6MB, SRP-275-6MB, SRP-280-6MB.

Parameters:

Rated Output Power
 at STC:

270W, 275W, 280W, 285W,
 290W, 295W, 300W, 305W,
 310W, 315W, 320W, 325W,
 330W, 335W, 340W, 225W,
 230W, 235W, 240W, 245W,
 250W, 255W, 260W, 265W,
 270W, 275W, 280W.

Application Class:

Class A

Max. System Voltage:

1000V DC

Test Laboratory:

Yangzhou Opto-electrical
 product testing institute
 No.10 West Kaifa Road, Yangzhou,
 225009 Jiangsu P.R.China

Construction:

Framed, with Junction box,
 cable and connector.

Fire Safety Class:

Class C

PID Test Condition:

±1000V DC, 96 h, 85% RH, 60°C

**Tested
 according to:**

IEC 61215(ed.2)
 IEC 61730-1(ed.1);am1;am2
 IEC 61730-2(ed.1);am1
 PPP 58042B:2015

**Production
 Facility(ies):**

76729